



## DESIGN OVERSIGHT

BEHZAD GOLEMOHAMMADI

CALCULATED BY  
DESIGNED BY  
CHECKED BYDATE REVISED BY  
PBP  
ABREVISED BY  
DATE REVISED BY  
PBP

## CONDUIT DATA

Conduit No	Reference	Size	Type	Total Fill (mm²)	Allowable Fill (mm²)	Included Cable No.	Conductor Type
3459	E-264	41	RGS-PVC coated conduit	102.61	534.55	Pull rope	Soft-Fiber Polyester
						UP210-9	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3459A	E-265	41					
3464	E-285	53	RGS-PVC coated conduit	145.44	879.42	UP210-1A-14	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-13	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3464A	E-286	53					
3500	E-284, E-274	53	RGS-PVC coated conduit	471.09	879.42	UP210-1A-1	3 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-1C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
						UP210-1A-2	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3501	E-282	53	RGS-PVC coated conduit	567.32	879.42	UP210-1A-1A	3 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-2	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-1C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
3502	E-284, E-274	78	RGS-PVC coated conduit	520.30	1935.24	UP210-1A-1B	3 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-2	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-1C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
3503	E-284, E-274	53	RGS-PVC coated conduit	808.99	879.42	Pull rope	Soft-Fiber Polyester
						UP210-1A-3C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-3	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-4	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3504	E-282, E-284, E-285	53	RGS-PVC coated conduit	520.30	879.42	UP210-1A-3C	3 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
						UP210-1A-3A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-4	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3505	E-284, E-274	53	RGS-PVC coated conduit	352.55	879.42	UP210-1A-4	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-3C	3 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
						UP210-1A-3B	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3506	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-5	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-5C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-6	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3507	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-6	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-5A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-5C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3508	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-5B	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-5C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-6	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3600	E-284, E-274	53	RGS-PVC coated conduit	387.11	879.42	UP210-1A-7	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-7C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
						UP210-1A-8	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3601	E-284, E-274	53	RGS-PVC coated conduit	483.34	879.42	UP210-1A-7C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-7A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-8	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester

REQUEST FOR INFORMATION NOT ADDRESSED IN THIS CCO REMAIN IN FORCE

1	02/19/08	ELECTRICAL MODIFICATIONS	MP	EL	RR	42
MARK DATE		DESCRIPTIONS	BY	CH'D	CCO#	

CONTRACT CHANGE ORDER NO.  
SHEET \_\_\_\_ OF \_\_\_\_

FOR REVISION ONLY

DIST	COUNTY	ROUTE	KILOMETER POST	SHEET NO	TOTAL SHEETS
04	SF	80	13.2/13.9	385R1	1204

Jens Erlingsson 12/19/02  
REGISTERED PROFESSIONAL ELECTRICAL ENGINEER  
JENS ERLINGSSON NO. 8249 Exp. 9/30/06  
STATE OF CALIFORNIA

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.

Caltrans now has a web site! To get to the web site, go to <http://www.dot.ca.gov>

## CONDUIT DATA

Conduit No	Reference	Size	Type	Total Fill (mm²)	Allowable Fill (mm²)	Included Cable No.	Conductor Type
3602	E-284, E-274	78	RGS-PVC coated conduit	436.32	1935.24	UP210-1A-8	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-7B	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-7C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
3603	E-284	53	RGS-PVC coated conduit	725.01	879.42	UP210-1A-10	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-9C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
						UP210-1A-9	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3604	E-284, E-285	78	RGS-PVC coated conduit	436.32	1935.24	Pull rope	Soft-Fiber Polyester
						UP210-1A-9C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-9A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-10	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3605	E-284, E-274	53	RGS-PVC coated conduit	337.90	879.42	UP210-1A-10	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-9B	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-9C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
3606	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-12	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-11	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-11C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3607	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-11A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-11C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-12	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
3608	E-284, E-274	53	RGS-PVC coated conduit	241.67	879.42	UP210-1A-12	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						UP210-1A-11B	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1A-11C	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
3700	E-284, E-275	53	RGS-PVC coated conduit	387.11	879.42	UP210-1B-1	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1B-2	2 + 1 gnd #12, #12, 600 V, RHH/RHW insulation
						Pull rope	Soft-Fiber Polyester
3701	E-284	53	RGS-PVC coated conduit	483.34	879.42	UP210-1B-1A	2 + 1 gnd #8, #10, 600 V, RHH/RHW insulation
						UP210-1B-2	2 + 1 gnd